

---

From: Richard Tatton-Bennett  
Sent: 24 May 2011 16:10  
To: Debbie Watson  
Subject: RE: Consultation on a Planning Proposal

Hi Debbie

Planning App. No. 11/00265/FUL

No Objections, observation, public surface water sewer is available which would be the preferred option rather than soakaways.

Regards

Richard

---

From: Debbie Watson  
Sent: 24 May 2011 14:49  
To: Richard Tatton-Bennett  
Subject: Consultation on a Planning Proposal

<< File: 11.00265.FUL.rtf >>