

26 MAY 2017

KEY



PERMEABLE BLACKTOP CONSTRUCTION
 SURFACE COURSE: 40mm OF BARDON 10mm AGGREGATE DRAIN ASPHALT
 BINDER COURSE: 60mm OF BARDON 20mm AGGREGATE DRAIN ASPHALT
 SUB-BASE: 450mm OF BARDON SUDsAGG



LIGHT DUTY BLACKTOP CONSTRUCTION
 SURFACE COURSE: 40mm THICK STONE MASTIC ASPHALT TO BS EN 13108-5:2007. MATERIAL DESIGNATION: SMA 10 SURF 40/60
 BINDER COURSE: 60mm THICK ASPHALT CONCRETE TO BS EN 13108-1:2007. MATERIAL DESIGNATION: AC 20 DENSE BIN 100/150
 SUB-BASE: 300mm THICK TYPE 1 SUB-BASE



PRECAST CONCRETE PAVING FLAGS
 SURFACE COURSE: 400x400mm PCC PAVING FLAGS
 LAYING COURSE: 30mm THICK SAND LAYING COURSE
 SUB-BASE: 225mm THICK TYPE 1 SUB-BASE



SOFT LANDSCAPING
 PLEASE REFER TO LANDSCAPE ARCHITECTS DESIGN

NOTES

1. CBR values anticipated to be 3%. If this is not achieved then please contact civil engineer.
2. Permeable blacktop construction to be provided within car parking spaces. Regular light duty blacktop construction to be provided within access road.
3. All retained utility covers and frames to be raised to proposed finished ground levels.

ARBORICULTURAL CONSULTANT TO CONFIRM STATUS OF EXISTING TREES (TPO).

Revision	Date	By	Chk
P01 Revision 1			

Client:
 Essex County Council
 Land Development Team

Project:
 S3 - 57 South Street

Drawing Title:
 Proposed Pavement Layout Plan

Suitability Status:
 S2 - Suitable for Information

Job No. 170097 Scale 1:100 Size A1 Rev P01

Drawing Number:
 000-PEV-XX-XX-DR-C-0700

Project Code - Originator - Zone - Level - Type - Role - Number

PICK
 EVERARD

T 0345 045 0050 www.pick-everard.co.uk

This drawing is issued for the sole and exclusive use of the intended recipient and is subject to copyright in favour of Pick Everard. Pick Everard does not accept any responsibility or liability whatsoever for its use by a person other than the intended recipient.